



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

Senco Products, Inc.
8485 Broadwell Road
Cincinnati, OH 45244

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SENCO DuraSpin™ Screws

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This consists of pages 1 through 3.

The submitted documentation was reviewed by Frank Zuloaga, RRC



NOA No 02-0607.02
Expiration Date: 07/31/07
Approval Date: 07/31/02
Page 1 of 3

ROOFING ASSEMBLY APPROVAL:

Category: Roofing
Sub Categories: Roofing Fasteners, Tile

1. SCOPE:

This approves **SENCO DuraSpin™ Screws**, as manufactured by Senco Products, Inc. described in Section 3 of this Notice of Acceptance, designed to comply with the Florida Building Code (FBC) High Velocity Hurricane Zone..

2. PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Senco DuraSpin™ Screws			
08D200W	#8 x 2"	TAS 114	Exterior Wood Screws with Weatherex II Plating
08D250W	#8 x 2-½"	TAS 114	Exterior Wood Screws with Weatherex II Plating
08D300W	#8 x 3"	TAS 114	Exterior Wood Screws with Weatherex II Plating

3. LIMITATIONS:

Senco DuraSpin™ Screws are approved for use with roof tile assemblies in compliance with section 1523.6.5.2.11 of the FBC..


EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Sub Tropical Testing	TAS 114, Appendix E, 1000 Hrs.	STTS02001	04/15/02



NOA No 02-0607.02
Expiration Date: 07/31/07
Approval Date: 07/31/02
Page 2 of 3

Figure 1



END OF THIS ACCEPTANCE

